

DIVERSIFIED TESTING LABORATORIES, INC.

WORLDWIDE SERVICE

----- "We Test Per Your Request"----

336 WEST FRONT STREET P.O. BOX 4004 BURLINGTON, NORTH CAROLINA 27215 PHONE (336) 227-7710 · FAX (336) 227-1175 www.diversifiedtestinglabs.com

June 15, 2015

Mr. Lee Hinsley GLOBAL PLASTIC SHEETING 1331 Specialty Drive Vista, CA 92081

Reference: Laboratory Test Report

Lab Identification No. 15474 Invoice No. 46287 (Attached)

Dear Mr. Hinsley:

One (1) sample, identified as ULTRA BLACK FR 8, was received and tested in accordance with the National Fire Prevention Association No. 701, "Standard Methods of Fire Tests for Flame Propagation of Textiles and Films, 2015 Edition, (Test 1, Small Scale)". The results are as follows:

Specimen Number	Residual Flame (<u>seconds</u>)	Weight Loss (<u>percent</u>)
1	0.0	5.48
2	0.0	4.71
3	0.0	8.52
4	0.0	0.17
5	0.0	3.56
6	0.0	6.91
7	0.0	3.12
8	0.0	5.71
9	0.0	6.98
10	0.0	7.02
AVG.	0.0	5.22

The sample submitted meets the minimum requirements of the above standard. The average percent weight loss cannot exceed 40% and the weight loss of individual specimens cannot exceed mean value plus three standard deviations. The average residual flame cannot exceed 2.0 seconds.

If there are any questions or when we can be of further assistance, please let us know.

Sincere

Brian S. Dement

BSD/mr Attachment